



TYPE B: LONG SIDE BEND TO TEE.

TYPE B MODIFIED: SHORT SIDE BEND TO TEE.

MAIN LINE	DIMENSION L	
	TYPE B	TYPE B MOD.
6"	24"	19"
8"	25"	20"
12"	28"	23"
16"	31"	26"

NOTE:

- FIRE HYDRANTS SHALL BE SET A MINIMUM OF 6' FROM ALL DRIVEWAY OPENINGS.
- * CREATE A DRY WELL AROUND HYDRANT DRAIN USING 1/4 YARD OF #57 GRAVEL. GRAVEL TO BE 18" ABOVE DRAIN HOLE.

Del-Co
Water Co., Inc.

6773 OLENTANGY RIVER RD.
DELAWARE, OH 43015

HYDRANT SETTING TYPE B

REVISED
6 JAN 15

SCALE
NTS

PAGE 1 OF 1

D-3

