


THE DRAWING ABOVE SHOWS A TYPICAL METER CROCK THAT WILL BE INSTALLED BY DEL-CO WATER ON THE CUSTOMER'S PROPERTY. TYPICALLY THIS METER PIT IS INSTALLED 5 FEET BEHIND THE ROAD RIGHT OF WAY LINE UNLESS YOUR PROPERTY IS LOCATED IN A PLATTED SUBDIVISION. IN THAT CASE THE CUSTOMER SHOULD CONTACT DEL-CO TO DETERMINE WHERE THE METER CROCK SHOULD BE LOCATED. DEL-CO WILL MAINTAIN RESPONSIBILITY FOR THE METER, CROCK, AND THE SERVICE LINE FROM THE CROCK TO THE WATER MAIN. CONSTRUCTION AND MAINTENANCE OF THE SERVICE LINE FROM THE CROCK TO THE HOUSE, INCLUDING THE CONNECTION TO THE SETTER, IS THE CUSTOMER'S RESPONSIBILITY.

DEL-CO DOES NOT REGULATE THE MATERIAL USED FOR THE CUSTOMER'S PORTION OF THE SERVICE LINE. HOWEVER, WE DO OFFER MINIMUM MATERIAL AND CONSTRUCTION RECOMENDATIONS FOR TYPICAL 5/8" X 3/4" RESIDENTIAL METER SERVICES.

1. USE 1-INCH IRON PIPE SIZE (I.P.S.) SDR 7 POLYETHYLENE PIPE WITH A MINIMUM WORKING PRESSURE OF 200 P.S.I. FOR SERVICE LINES LESS THAN 500 FEET.
2. USE 2-INCH SDR 21 PVC PIPE WITH A WORKING PRESSURE OF 200 P.S.I. FOR SERVICE LINES OVER 500 FEET.
3. USE STAINLESS STEEL INSERTS AND BRASS COMPRESSION COUPLINGS FOR ALL POLYETHYLENE PIPE CONNECTIONS.
4. BURY SERVICE LINES A MINIMUM OF 36 INCHES DEEP.

CONNECTION OF THE CUSTOMER'S SERVICE LINE TO THE METER IS THE CUSTOMER'S RESPONSIBILITY. HOWEVER, IF THE CUSTOMER CONSTRUCTS THE SERVICE LINE PRIOR TO THE CROCK BEING SET AND USES THE PIPE SPECIFIED ABOVE, DEL-CO WILL MAKE THE CONNECTION AS A COURTESY WHEN THE CROCK IS INSTALLED. IF OTHER PIPE MATERIALS ARE USED, DEL-CO MAY MAKE THE CONNECTION TO THE CUSTOMER'S SERVICE LINE IF THE CUSTOMER PROVIDES THE PROPER ADAPTER FITTING AND PRIOR ARRANGEMENTS ARE MADE WITH OUR DISTRIBUTION DEPARTMENT. IF DEL-CO IS UNABLE TO CONNECT YOUR SERVICE LINE TO THE METER SETTER, DEL-CO WILL NOT RETURN TO YOUR PROPERTY TO MAKE THAT CONNECTION.

IF THE METER IS INSTALLED PRIOR TO THE INSTALLATION OF THE CUSTOMER'S SERVICE LINE, DEL-CO WILL PROVIDE A 4 FOOT LONG 1-INCH IRON PIPE SIZE(I.P.S.) SDR 7 POLYETHYLENE PIGTAIL FOR THE CUSTOMER TO CONNECT TO THEIR SERVICE LINE. IF THE CUSTOMER DESIRES THE METER CROCK TO BE INSTALLED PRIOR TO THE INSTALLATION OF THEIR SERVICE LINE, THE CUSTOMER SHOULD MARK THE DESIRED LOCATION OF THE CROCK WITH A WOOD STAKE LABELED "DEL-CO".



**Del-Co
Water Co., Inc.**
6773 OLENTANGY RIVER RD.
DELAWARE, OH 43015

TYPICAL METER INSTALLATION

REVISED
11-4-05

SCALE
NTS

PAGE 1 OF 1